

## Questions and Answers

### RFQ/CAI/075/2023 for WATER TANK AND SEWAGE SYSTEM - ARGEEN

Following are received questions and answers regarding the subject RFQ.

1. Depth of the existing water well is 150 m, please confirm. عمق البئر  
  - Confirmed 150 meters.
2. Diameter of the well sleeve and pipes ما هو قطر مواسير البئر  
  - 3 inches
3. Recall / dismantle of the existing submersible water pump is required?  
  - نعم أكيد لابد من رفع المواسير القديمة بالظلمبة القديمة لتركيب الظلمبة الجديدة ونزول مواسير البئر مرة أخرى
  - Yes, dismantling of old pump and installation of new pump is required
4. Any mechanical excavation for surface and leveling is required? هل نحتاج اي اعمال حفر ميكانيكي  
بالبريمة?  
  - No, not required.
5. The way of pricing for any additional required materials? (remeasured or lumpsum ).  
  - Normally, no additional work will be required, however, if happened, then the supplier should not execute any additional work unless he contacts the supply unit and receives an official approval to execute the additional work.
6. For the pump of the water well, is it stainless steel or zenit?  
  - Stainless steel
7. Water motor of the tank, should be inside or outside?  
  - To be outside the tank.