


ANNEX-B
SCOPE OF WORK

DETAILED SPECIFICATION OF THE REQUIRED ITEMS

S.NO	ITEM	SPECIFICATION	QTY	UOM
1	UPS	<ol style="list-style-type: none">1. UPS 120 KVA online without battery bank for medical device.2. UPS should be compatible with existing batteries bank (40 Blocks Bank AGM)3. Input protection require for UPS 08 ATS panel for generator connection4. Installation and Commissioning 	01	NO

ANNEX-C

PRICE PROPOSAL					
Sr. No	Description/Equipment	Qty	UOM	Unit Cost	Total Amount
1	UPS with Commissioning and Installation	1	NO		
	GRAND TOTAL				

DATE: _____

NAME: _____

COMPANY NAME: _____

SIGNATURE: _____

IN THE CAPACITY OF (TITLE): _____